

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7770-1621:100

Page 1 of 1

CATEGORY: Valves/Switches

LISTEE: Anvil International, Inc. 110 Corporate Dr, Suite 10, Portsmouth, NH 03802-3180
Contact: Michael Horgan (401) 349-3020 FAX (401) 233-8142

DESIGN: Model 78 FP 2, 2½, 3, 4, 5, 6, 8, 10, and 12 inch grooved end check valves, 300 psig rated working pressure for horizontal and vertical installation. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, working pressure, and UL label.

APPROVAL: Listed as a check valve for use with fire sprinkler systems. Refer to listee's Installation Instruction Manual for details.

11-25-03



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 22, 2004

*Listing Expires **June 30, 2005***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager